

TWISS LABORATORIES

26276 Twelve Trees Lane, Suite C Poulsbo, WA 98370 Telephone (360) 779-5141 FAX (360) 779-5150

IOC - SHORT

IOC - SHORT by Various EPA Approved Methods

Source / Point of Entry - Report of Analysis

Date Collected: 6/3/2015 System ID No: IH3826 Lab - Sample #: 01088301 Sample Location: CA-2E Sample Purpose: I Sample Composition: S Send Report To: Eugene Purser Port Gamble S'Klallam Tribe 31912 Little Boston Rd NE Kingston, WA 98346	Group: A System Name: 7 Cedars Casino County: Clallam DOH Source No: Date Received: 6/3/2015 Date Analyzed: 6/5/2015 Date Reported: 6/10/2015 Sample Type: Post-treatment/Finished Collected By: Ian Jones Phone Number: 360-477-8673 Bill To: Eugene Purser Port Gamble S'Klallam Tribe 31912 Little Boston Rd NE Kingston, WA 98346
--	---

DOH#	Analyte	Results	Units	SRL	Trigger	MCL*	MCL Exceeded	Method (Analyst Init.)
405	Calcium	27.4	mg/L	0.05				EPA 200.7 (KW)
16	Conductivity	308	uS/cm	70		700		SM 2510 B (KW)
403	Alkalinity	155	ug/L as CaCO ₃	3				SM 2320 B (KW)

SRL: (State Reporting Level), indicates the minimum reporting level required by the Washington Department of Health (DOH).

Trigger Level: DOH Drinking Water response level. Systems with compounds detected at concentrations in excess of this level are required to take additional samples. Contact your regional DOH office for further information.

MCL: (Maximum Contaminant Level), If the contaminant amount exceeds the MCL, immediately contact your regional DOH office.

NA: (Not Analyzed), in the results column indicates this compound was not included in the current analysis.

ND: (Not Detected), in the results column indicates this compound was analyzed and not detected at a level greater than or equal to the SRL.

< (0.00x): indicates the compound was not detected in the sample at or above the concentration indicated.

***** The 0.010 mg/L MCL for Arsenic is for Group A NTNC systems. All other systems should check with their county Health District to determine what level is applicable.

TWISS LABORATORIES

26276 Twelve Trees Lane, Suite C Poulsbo, WA 98370 Telephone (360) 779-5141 FAX (360) 779-5150

IOC - SHORT

IOC - SHORT by Various EPA Approved Methods

Source / Point of Entry - Report of Analysis

Date Collected: 6/3/2015 System ID No: IH3826 Lab - Sample #: 01085901 Sample Location: CA-03 Sample Purpose: I Sample Composition: S Send Report To: Jamestown S'Klallam Tribe 1033 Old Blyn Hwy Sequim, WA 98382	Group: A System Name: 7 Cedars Casino County: Clallam DOH Source No: Date Received: 6/3/2015 Date Analyzed: 6/3/2015 Date Reported: 6/10/2015 Sample Type: Post-treatment/Finished Collected By: Ian Jones Phone Number: 360-477-8673 Bill To: Jamestown S'Klallam Tribe 1033 Old Blyn Hwy Sequim, WA 98382
---	--

DOH#	Analyte	Results	Units	SRL	Trigger	MCL*	MCL Exceeded	Method (Analyst Init.)
16	Conductivity	313	µS/cm	70		700		SM 2510 B (DT)
405	Calcium	27.8	mg/L	0.05				EPA 200.7 (KW)
403	Alkalinity	146	µg/L as CaCO ₃	3				SM 2320 B (KW)

SRL: (State Reporting Level), indicates the minimum reporting level required by the Washington Department of Health (DOH).

Trigger Level: DOH Drinking Water response level. Systems with compounds detected at concentrations in excess of this level are required to take additional samples. Contact your regional DOH office for further information.

MCL: (Maximum Contaminant Level), If the contaminant amount exceeds the MCL, immediately contact your regional DOH office.

NA: (Not Analyzed), in the results column indicates this compound was not included in the current analysis.

ND: (Not Detected), in the results column indicates this compound was analyzed and not detected at a level greater than or equal to the SRL.

< (0.00x): indicates the compound was not detected in the sample at or above the concentration indicated.

***** The 0.010 mg/L MCL for Arsenic is for Group A NTNC systems. All other systems should check with their county Health District to determine what level is applicable.